

**FLORIDA UNIFIED CITATIONS DICTIONARY
FOR
WATER WELL CONSTRUCTION**

OCTOBER 2002

COMPILED BY

THE FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

AND

THE WATER WELL CONTRACTOR WORK GROUP

HISTORY

Draft	4/89
Revision	7/89
Revision	8/89
Revision	8/90
Revision	3/92
Revision	9/92
Revision	10/02

TABLE OF CONTENTS

Introduction	2
Index to Main Subject Title	3
Citations Dictionary	5
Appendices	37
A	NWFWMD 40A-3, F.A.C.....	A1
B	SRWMD 40B-3, F.A.C.....	B1
C	SJRWMD 40C-3, F.A.C.	C1
D	SWFWMD 40D-3, F.A.C.	D1
E	SFWMD 40E-3, F.A.C.....	E1
F	FDEP 62-532, F.A.C.	F1
G	FDEP 62-531, F.A.C. and Disciplinary Guidelines and Procedures Manual	G1
H	FDEP 62-555, F.A.C.	H1
I	FDEP 62-524, F.A.C.	I1
J	DOH 64E-8, F.A.C.....	J1
K	C Casing Standards Referenced in Water Well Construction Rules	K1

INTRODUCTION

The Florida Unified Citations Dictionary for Water Well Construction was developed by the Florida Department of Environmental Protection (FDEP), Chapter 62-531, F.A.C., Rule Development Committee. Where possible, the citations were standardized and combined to provide for efficient enforcement. This process also encourages equitable enforcement statewide.

The citations provide a standard numbering system, which will be used to produce the monthly clearinghouse of water well construction violations. Each violation will have a unique number that will be used by each permitting authority to provide uniform enforcement information across jurisdictional boundaries.

The dictionary in its complete form will include all the applicable rules governing water well construction, the guidelines and procedures standardizing enforcement practices, and the standards referenced by the rules. A loose-leaf format will allow easy updating.

The index allows rapid searches for applicable citations using a common word listing. These main subject titles are cross-referenced to citation numbers.

Each citation number is followed by a list of applicable rule citations for all permitting authorities.

The text portion gives the wording that will be used on each enforcement action of the rule applicable to the violation alleged. Slight differences in rule language among the permitting authorities require the use of several text statements under the same citation number. Each group of text statements is identical in subject and direction therefore allowing the use of one citation number. In the right column, two numbers are displayed. The first is the recommended monetary penalty. The second number refers to the points assessed against the contractor when a final agency action is taken. A Permitting Authority may use an informal Warning Letter in lieu of formal enforcement action.

The Chapter 62-531, F.A.C., Committee will meet periodically to decide on statewide changes in the program, to approve changes in the citations dictionary and to schedule points reduction workshops for the coming calendar year.

INDEX OF MAIN SUBJECT TITLES

A

Abandonment, General	<i>Citation 41</i>
Abandonment, Methods	<i>Citation 120</i>
Abandonment, Permit Due to Unsuitability for Use	<i>Citation 22</i>
Abandonment, Restore Hydrologic Conditions	<i>Citation 123</i>
Abandonment, Suitable Use or Standards Violation	<i>Citation 121</i>
Abandonment, Timeframe	<i>Citation 122</i>
Additional Information Requests	<i>Citation 20</i>
Address Change	<i>Citation 8</i>

C

Casing, Approved Materials	<i>Citation 60, 61</i>
Casing, Below Water Level	<i>Citation 78</i>
Casing, Caving Zones or Screen, Caving Zones	<i>Citation 81</i>
Casing, Condition	<i>Citation 59</i>
Casing, Dimension	<i>Citation 63, 64</i>
Casing, Drive Shoe	<i>Citation 62</i>
Casing, Extension	<i>Citation 79, 80</i>
Casing, Non-Metallic and Stainless Installation	<i>Citation 65</i>
Casing, Overlap	<i>Citation 84</i>
Casing, Sand Production or Screen, Sand Entrance	<i>Citation 82</i>
Casing, Telescoped, Centralizers	<i>Citation 83</i>
Change of Permitted Location	<i>Citation 21</i>
Completion Report Accuracy	<i>Citation 33</i>
Completion Report Submittal	<i>See. Citation 32</i>
Conjunctive Permit Requirements	<i>Citation 9, 10</i>
Construction without a Permit	<i>Citation 12, 13, 14, 15</i>
Contamination, Backflow Prevention	<i>Citation 85</i>
Contamination, Clean Work Site	<i>Citation 67</i>
Contamination, General	<i>Citation 45, 46</i>
Contamination, Tanks Monitor Well Standards	
Chapter 62-761, F.A.C.	<i>Citation 49, 50, 51</i>

Contamination, Verification and Exemption Requirements for Spacing Standards	<i>Citation 57, 58</i>
Contamination, Well Location Standards	<i>Citation 52</i>
Contamination, Well Spacing Standards	<i>Citation 53, 54</i>

D

Disinfection, After Construction	<i>Citation 70, 71</i>
Disinfection, General	<i>Citation 68, 69</i>
Display of License	<i>Citation 7</i>
Display of Permit	<i>Citation 23</i>
Drilling Records, Any Well, Inspection at any Reasonable Time	<i>Citation 35</i>
Drilling Samples	<i>Citation 37</i>

E

Emergency Permit Requirements	<i>Citation 18</i>
Exemption/Variations, Standard	<i>Citation 24</i>
Explosives, Approval of	<i>Citation 118</i>

F

Field Log, Any Well, Maintain During Construction	<i>Citation 34</i>
Flowing Wells, Valve Controls	<i>Citation 119</i>

G

Grouting	<i>Citation 93</i>
Grouting, Annular Seal	<i>Citation 86, 87</i>
Grouting, Centering Casing	<i>Citation 104</i>
Grouting, Combination Wells, Pilot Hole Driving	<i>Citation 98</i>
Grouting, Confining Beds Absent, Special Criteria (SRWMD)	<i>Citation 94</i>

Grouting, Lost Circulation	<i>Citation 110</i>
Grouting, Methods	<i>Citation 100, 101</i>
Grouting, Mixing Requirements	<i>Citation 102</i>
Grouting, Public Supply Well Criteria	<i>Citation 92</i>
Grouting, Set Time	<i>Citation 105</i>
Grouting, Special Criteria (NFWWMD)	<i>Citation 89, 90</i>
Grouting, Special Criteria (SJRWMD) (SWFWMD)	<i>Citation 91</i>
Grouting, Special Criteria, Telescoped Casing (SJRWMD)	<i>Citation 109</i>
Grouting, Telescoped Casing	<i>Citation 107, 108</i>
Grouting, Unconsolidated	<i>Citation 95, 96</i>
Grouting, Upper Three Feet, Driven Casing	<i>Citation 99</i>

H

Homeowner Exemption	<i>Citation 6</i>
---------------------	-------------------

I

Improper Use of a Contractor's License	<i>Citation 4, 5</i>
Inspection Report	<i>Citation 115</i>
Inspections for Standards Compliance	<i>Citation 38</i>
Inspections, Identification Tags	<i>Citation 39</i>

M

Maintaining a Contractor's License	<i>Citation 1, 2</i>
------------------------------------	----------------------

N

Notification, Public Supply Construction	<i>Citation 42</i>
--	--------------------

P

Permit Timeframes	<i>Citation 26</i>
Permits, Condition Violations	<i>Citation 29</i>
Permits, Incomplete Application	<i>Citation 27</i>

R

Report, Test Well Requirements	<i>Citation 36</i>
--------------------------------	--------------------

S

Screen Seal	<i>Citation 76, 77</i>
Screen, Unconsolidated	<i>Citation 73</i>

T

Telescoped Casing, Centralizers, Public Supply Well	<i>Citation 43</i>
---	--------------------

V

Variances, Oral	<i>Citation 25</i>
-----------------	--------------------

W

Water Well Violation, General	<i>Citation 31</i>
Well Apron, Public Supply	<i>Citation 44</i>
Well Casing Terminus, Above Grade Installation	<i>Citation 74</i>
Well Casing Terminus, Below Grade Installation	<i>Citation 75</i>
Well Seal, Permanent, Above Flood Level	<i>Citation 113</i>
Well Seal, Pump Installed	<i>Citation 116</i>
Well Seal, Temporary, Penetrating to Aquifer	<i>Citation 111</i>
Well Vent, Above Flood Level	<i>Citation 114</i>

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Maintaining a Contractor's License		
1	40A-3.038(1)(a) 40B-3.038(1)(a) 40C-3.011(4) 40C-3.038(1) 40D-3.037(1)(2) 40D-3.038(3) 40E-3.038(1)(2) 62-531.450(2)(a),(4)(f)	Practice water well contracting without an active license or with a revoked, suspended, or inactive license.	1000	10
2	40A-3.038(1)(b) 40C-3.038(1) 40D-3.037(1) 40E-3.038(1)(2) 62-531.450(2)(c)	Failure to provide truthful information or make truthful statements in an application for a Water Well Contractor's License.	1000	10
		Improper Use of a Contractor's License		
3	40A-3.038(1)(h) 40C-3.038(1) 40D-3.037(1) 40E-3.038(1)(2) 62-531.450(4)(c)	Allowing any other person to use the licensee's license.	1000	10
4	40A-3.038(1)(i) 40B-3.341(3) 40C-3.532(1)(a) 40E-3.038(1)(2)	Failure to comply with any provision of Chapter 373, Part III, F.S. any rule adopted by the District or any order of the District. Note: An unlicensed water well contractor may be issued a CEASE AND DESIST ORDER as authorized by Chapter 73.323(7), F.S., and cited above.	500	5
5	Reserved			

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY POINTS	
		Homeowner Exemption		
6	40C-3.051(3) 40D-3.301(1)(a) 62-531.390(2)	Failure to comply with all rules relating to the construction standards of water wells subject to the exemption for private wells two inches or under in diameter intended for their own use.	500	N/A
		Display of License		
7	40A-3.038(1)(d) 40B-3.038(1)(c) 40C-3.038(1)(e) 40D-3.037(1) 40E-3.037 62-531.380(2)	Failure to display contractor license number on both sides of each piece of drilling equipment owned, leased, or operated by the contractor.	100	1
		Address Change		
8	40A-3.038(1)(e) 40B-3.038(1)(e) 40C-3.038(1) 40D-3.037(1) 40E-3.037	Failure to notify the District of any change.	100	1
		Conjunctive Permit Requirements		
9	40A-3.041(4) 40C-3.301(4) 40D-3.045(1) 40E-3.051 40E-3.301(3)(b)	Construction of a well for which a water or consumptive use permit is required prior to issuance of the water use permit.	500	5
10	40A-3.041(2) 40C-3.051(2)	Failure to obtain an artificial recharge permit prior to constructing an injection well.	500	5
11	Reserved			

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Construction without a Permit		
12	40A-3.038(1)(g) 40A-3.041(1) 40B-3.041 40C-3.041 40C-3.492(1)(b),(c) 40D-3.041(1) 40E-3.041(1) 64E-8.002(2)	Failure to obtain a permit prior to the construction, repair or abandonment of a water well within the District, not exempted by the rule.	500	5
	40E-3.041(2)	Failure to obtain a water well construction permit for any gang well regardless of size other than for dewatering.	500	5
13	40C-3.041(5) 40D-3.041(1)(e) 40E-3.041(1) 64E-8.002(2) 62-555.510(1,2)	Failure to obtain a water well construction permit prior to the construction, repair or abandonment of any public water supply well.	1000	10
14	Reserved			
15	40A-3.041(15) 40C-3.041(4) 40E-3.041(3)	Failure to obtain a water well construction permit to convert to a test hole to a water well, not exempted by rule.	500	5
	40E-3.041(4) 40C-3.041(4)	Failure to obtain or modify a water well construction permit to convert a monitor or observation well to a production well.	500	5
	62-532.400(1)	Failure to obtain a permit before beginning construction, repair or abandonment of any water well.	500	5
16	Reserved			
17	Reserved			

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Emergency Permit Requirements		
18	40A-3.451(3)	Failure to submit \$25 fee and standard fee with all emergency permit applications.	100	1
	40A-3.451(4)	Failure to submit the required permit application and written explanation of emergency within 24 hours of emergency authorization.	100	1
	40B-3.451	Failure to submit the application and fee within ten (10) days of issuing an oral emergency authorization.	100	1
	62-532.420(2)	Failure to submit a permit application in writing within 10 days after an emergency permit application is granted.	100	1
	40D-1.1022(3)	Failure to submit the application and fee within 48 hours of issuing an oral emergency authorization.	100	1
	40C-1.1010(3) 40C-3.451 40E-3.451(3)	Failure to submit the permit application and fee within twenty-four hours after an emergency permit has been issued verbally.	100	1
19	Reserved			
		Additional Information Requests		
20	40A-3.041(5) 40C-3.101(5)(a) 40D-3.037(1),(2) 62-532.400(2)(b)	Failure to supply additional information as requested.	100	1
		Change of Permitted Location		
21	40A-3.041(9) 40D-3.037(1),(2) 62-532.400(5)	Failure to apply for an amended permit prior to changing well location.	250	2.5

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
Abandonment, Permit Due to Unsuitability for Use				
22	40A-3.041(12) 40D-3.531(4)	Failure to obtain a permit to abandon a well which has been drilled and found to be unsuitable for its intended use.	500	5
Display of Permit				
23	40A-3.041(8) 40C-3.461(5) 40D-3.041(2) 62-532.400(4)	Failure to make the permit application available for inspection at the site during construction, repair, or abandonment of a well.	100	1
Exemption/Variances, Standard				
24	40A-3.051(2)	Failure to follow the provisions of an exemption to 40A-3 rules.	500	5
	40B-3.051(3) 40B-3.0511(5) 40C-3.455(4) 40D-1.1001(4) 40E-3.0511(6)	Failure to comply with special conditions issued with a construction variance.	500	5
Variances, Oral				
25	40B-3.0511(4) 40C-3.455(5) 40D-1.1022(3) 40E-3.0511(4)	Failure to apply for proper a permit after being granted an oral variance.	100	1
		Note: SFWMD requires a written request from the applicant within 10 days of an oral variance.		
		Note: SJRWMD requires an application and fee within 24 hours of an oral variance for a well without a permit. The SJRWMD requires documentation on completion reports within 30 days if the well was previously permitted.		

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Permit Timeframes		
26	40A-3.321 40B-3.321 40C-3.321(2) 40D-3.321(2),(3) 40E-3.321 62-532.400(6)	Failure to request an extension prior to expiration of a permit, in the event construction, repair, or abandonment is not complete.	250	2.5
		Permits, Incomplete Application		
27	40C-3.301(6) 40C-3.492(1)(b)	Failure to provide accurate information through intentional misrepresentation when applying for a permit.	1000	10
	40A-3.492(1)(b) 40B-3.341(1) 40C-3.301(6) 40D-3.341(1) 40E-3.341(1)(a)	Failure to provide accurate information when applying for a permit.	250	2.5
28	Reserved			
		Permits, Condition Violations		
29	40A-3.492(1)(d) 40B-3.341(2) 40B-3.492(1)(b) 40C-3.492(1)(g) 40C-3.502(1)(c) 40D-3.301(2) 40D-3.341(2) 40E-3.341(1)(b)	Failure to comply with permit conditions.	500	5
30	Reserved			

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Water Well Violation, General		
31	Reserved			
		Completion Report Submittal		
32	40B-3.411(1) 40B-3.492(1)(c) 40C-3.411(1) 40C-3.492(1)(a) 40E-3.411(1),(3) 62-532.410	Failure to submit a completion report within 30 days after well completion.	100	1
	40A-3.411(1) 40C-3.492(1)(f) 40D-3.411(1)(a)	Failure to submit a completion report within 30 days after permit expiration.	100	1
	40C-3.411(3)	Failure to notify that work was not performed or completed within 30 days of the expiration of the permit.	100	1
		Completion Report Accuracy		
33	40C-3.492(1)(b)	Failure of the licensed contractor to file an accurate completion report through intentional misrepresentation.	1000	10
	40A-3.411(5) 40A-3.492(1)(f) 40B-3.411(2) 40B-3.492(1)(d) 40C-3.492(1)(a) 40D-3.411(1)	Failure of the licensed contractor to file an accurate completion report.	250	2.5
	40E-3.411(1)	Failure of the licensed contractor to file a fully completed well completion report.	100	1

(continued next page)

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
	40B-3.411(1) 40C-3.411(1)(a)	Failure to submit a corrected completion report as required by written notice within the given timeframe.	250	2.5
	40A-3.411(4) 40D-3.411(1)(a),(b)	Failure to use appropriate completion report form.	100	1
	40A-3.411(4)	Failure of well contractor to provide copy of completion report to well owner.	100	1
		Field Log, Any Well, Maintain During Construction		
34	40B-3.411(2) 40B-3.461(6) 40C-3.411(2) 40C-3.492(1)(d),(e) 40D-3.411(2) 40E-3.411(2)	Failure to maintain a field log on-site for any well during construction, repair or abandonment activities.	100	1
		Drilling Records, Any Well, Inspection at any Reasonable Time		
35	40C-3.461(7) 40B-3.411(2)	Failure to allow inspection of drilling records upon reasonable notice to a Licensed Contractor.	150	1.5
		Report, Test Well Requirements		
36	Reserved			
		Drilling Samples		
37	40A-3.492(1)(d) 40B-3.492(1)(e) 40B-3.411(4) 40C-3.492(1)(g) 40C-3.411(4) 40D-3.037(1)	Failure to provide drilling samples when required.	250	2.5

(continued next page)

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
	40D-3.341(2) 40E-3.411(4)	Failure to provide drilling samples when required.	250	2.5
		Inspections for Standards Compliance		
38	40A-3.461(1) 40B-3.461(1) 40C-3.461(1) 40D-3.461(1) 40E-3.461(1) 62-532.510(1)	Failure to allow access to inspect any well to insure conformity with applicable standards.	350	3.5
		Inspections, Identification Tags		
39	40C-3.461(3) 40C-3.492(1)(j)	Failure to place a tag on any well drilled in the District.	100	1
40	Reserved			
		Abandonment, General		
41	40A-3.341(3) 40A-3.531(1,4,5) 40B-3.461(5) 40C-3.461(6) 40C-3.531(1) 40D-3.037(1) 40D-3.461(4) 40D-3.531 40E-3.461(5) 40E-3.531(1,2,3) 64E-8.002(2)(c)	Failure to plug an abandoned well in accordance with the rules of the applicable Permitting Authority.	1000	10
	40C-3.502(1)(b)	Failure to plug a test hole or exploratory well.	1000	10

(continued next page)

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
	40C-3.517(10)	Failure to clear objects from all wells prior to grouting.	1000	10
	62-532.500(4)	Failure to plug a well from bottom to top with neat cement grout or bentonite and capped with a minimum of one foot neat of cement grout.	1000	10
		Notification, Public Supply Construction		
42	40A-3.461(4) 40B-3.492(1)(f) 40B-3.461(4) 40C-3.461(5) 40C-3.492(1)(h),(i) 40D-3.461(5)(a) 40E-3.461(4)	Failure to notify the District 24 hours prior to commencing drilling operations or placement of grout for a Public Supply Well.	500	5
		Telescoped Casing, Centralizers, Public Supply Well		
43	40A-3.502 40C-3.041(5) 40C-3.512(5)(a) 40D-3.507(3)(b) 62-532.500(2)(c)	Failure to provide at least two (2) centralizing spacers on overlapped telescoping casing in Public Water Supply wells.	500	5
		Well Apron, Public Supply		
44	40A-3.502 40C-3.041(5) 40D-3.037(1) 62-532.500(3)(c)	Failure to provide a 6' x 6' concrete pad around the wellhead on Public Water Supply Wells.	150	1.5
		Contamination, General		
45	40A-3.502 40A-3.512(1),(2) 40B-3.502	Failure to prevent uncontrolled surface flow to an aquifer or zone within an aquifer.	1000	10
		(continued next page)		

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
	40B-3.512(1),(2) 40C-3.502(1) 40C-3.512(1),(2) 40D-3.502 40E-3.502	Failure to prevent uncontrolled surface flow to an aquifer or zone within an aquifer.	1000	10
	62-532.500(2)(d)	Failure to prevent an interchange of water between water bearing zones which may result in deterioration of the quality of water in one or more water bearing zones.	1000	10
46	40A-3.502(2) 40C-3.502(1)(c),(d) 40D-3.502(5) 64E-8.002(2)(b)	Failure to meet designated special construction criteria area requirements, such as those established by Chapter 62-524.	1000	10
	62-532.400(7), Table 1	Failure to place the water well to comply with the setback distances in Table 1.	1000	10
	62-555	Failure to met the sanitary setback distances for public water systems.	1000	10
47	Reserved			
48	Reserved			
		Contamination, Tanks Monitor Well Standards, 62-761, F.A.C.		
49	40C-3.502(1)(a) 40D-3.502(3)	Failure to comply with requirements of Ch. 62-761.	500	5
50	Reserved			
51	Reserved			

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
Contamination, Well Location Standards				
52	40A-3.504(1) 40B-3.504 40C-3.502(1) 40D-3.505(1) 40E-3.504	Failure to locate a well so as not to pose a threat of contamination to the water resources.	1000	10
	40B-3.504 40C-3.502(2) 40D-3.505(2) 40E-3.504	Failure to comply with well location standards of Ch. 62-532.	1000	10
Contamination, Well Spacing Standards				
53	40A-3.504(3)(a)	Failure to locate an irrigation well at least 75 feet from a sanitary hazard.	500	5
	40A-3.504(3)(e)	Failure to locate a domestic well 175 feet from storage and treatment areas of livestock farms.	1000	10
54	Reserved			
55	Reserved			
56	Reserved			
Contamination, Verification and Exemption Requirements for Spacing Standards				
57	40A-3.504(6)	Failure to verify, prior to domestic well placement in a subdivision platted after 1972, that the criteria listed in 40A-3.504(2)(e) are met.	500	5
58	40A-3.504(5)	Failure to obtain an exemption from Chapter 40A-3 prior to constructing a well which would violate setback requirements.	500	5
	40D-3.505(4)	Failure to obtain an exemption from chapter 40D-3 prior to constructing a well which would violate setback requirements.	500	5

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Casing, Condition		
59	40A-3.507(1) 40B-3.507(1) 40C-3.507(1) 40D-3.037(1) 40E-3.507(1) 62-532.500(1)(a)	Failure to use casing and liner pipe that is in new or in like new condition.	1000	10
		Casing, Approved Materials		
60	40A-3.507(1) 40B-3.507(1) 40C-3.507(1) 40D-3.037(1) 40E-3.507(1) 62-532.500(1)	Failure to use approved casing and liner materials.	1000	10
61	40A-3.507(2, 6) 40B-3.507(2, 6) 40C-3.507(7),(8)(a) 40D-3.037(1) 40E-3.507(7) 62-532.500(1)(h,i)	Failure to join casing and liner pipe in an approved manner.	1000	10
		Casing, Drive Shoe		
62	40A-3.507(2) 40B-3.507(2) 40C-3.507(8)(a) 40C-3.517(11)(b) 40D-3.037(1) 40E-3.507(8)(a) 62-532.500(1)(i)	Failure to use a drive shoe when installing casing by driven methods.	500	5

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY POINTS	
		Casing, Dimension		
63	40A-3.507(3,4,5) 40B-3.507(3,5) 40C-3.507(1,3,4,5,6) 40D-3.037(1) 40D-3.507(1,2) 40E- 3.507(1),(2),(3),(5),(6) 62-532.500(1)(b,c,d,e,g)	Failure to meet casing or liner pipe standards.	1000	10
64	Reserved			
		Casing, Non-Metallic and Stainless Installation		
65	40A-3.507(7) 40B-3.507(7) 40C-3.507(8) 40D-3.037(1) 40E-3.507(8) 62-532.500(1)(i)	Failure to install non-metallic and stainless well casing or liner in an approved manner.	1000	10
66	Reserved			
		Contamination, Clean Work Site		
67	40A-3.512(1) 40B-3.512(1) 40C-3.512(1) 40D-3.502(2) 40E-3.512(1)	Failure to maintain a reasonably sanitary work site to prevent contamination of the resource.	350	3.5
		Disinfection, General		
68	40A-3.512(1) 40B-3.512(1)	Failure to maintain contaminant free make-up water.	1000	10

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
	40C-3.512(1)(a) 40D-3.502(2) 40E-3.512(1)	Failure to maintain contaminant free make-up water.	1000	10
69	40C-3.512(1)(b)	Failure to follow disinfection requirements for filter pack materials.	600	6
		Disinfection After Construction		
70	40A-3.512(6) 40C-3.512(1)(c)	Failure to properly clean and disinfect all water wells provided for potable use.	400	4
71	40C-3.512(1)(d)	Failure to follow disinfection requirements for non-potable wells.	250	2.5
72	Reserved			
		Screen, Unconsolidated		
73	40A-3.512(3,7) 40B-3.512(3) 40C-3.512(3) 40D-3.037(1) 40E-3.512(3) 62-532.500(2)(a)	Failure to use a screen in an unconsolidated stratum.	500	5
	40A-3.512(3) 40B-3.512(3) 40C-3.512(3) 40D-3.037(1) 62-532.500(2)(a)	Failure to extend casing in an unconsolidated stratum from land surface continuously to the screen.	500	5

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Well Casing Terminus, Above Grade Installation		
74	40E-3.512(3) 40D-3.037(1)	Failure to extend casing from above top of grade to the well screen in unconsolidated aquifers.	500	5
	40A-3.512(8) 40D-3.521(2) 62-532.500(3)(b)2,3,4	Failure to extend well casing at least 12 inches above grade, unless an exemption has been granted.	500	5
		Well Casing Terminus, Below Grade Installation		
75	40C-3.512(6)(a) 40D-3.037(1) 62-532.500(3)(b)2	Failure to follow criteria for below grade casing installation.	500	5
		Screen Seal		
76	40A-3.512(3) 40B-3.512(3) 40C-3.512(3) 40D-3.037(1) 40E-3.512(3)(a) 62-532.500(2)(a)	Failure to attach the well screen with a watertight seal.	500	5
	40B-3.512(3) 40C-3.512(3)	Failure to seal the terminus of a well screen in an unconsolidated stratum.	500	5
77	Reserved			
		Casing, Below Water Level		
78	40A-3.512(4) 40B-3.512(4) 40C-3.512(4)(a),(7)(a) 40D-3.037(1)	Failure to install casing to or below the static water level of the producing aquifer.	500	5
		(continued next page)		

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
	40E-3.517(4) 62-532.500(2)(b)	Failure to install casing to or below the static water level of the producing aquifer.	500	5
	40C-3.512(7)(b)	Failure to follow requirements for casing in a chert area.	500	5
		Casing, Extension		
79	40A-3.512(4) 40B-3.512(4) 40C-3.512(4)(a) 40D-3.037(1) 40E-3.512(4) 62-532.500(2)(b)	Failure to extend a continuous casing in a consolidated stratum from above land surface to the producing aquifer.	500	5
80	40C-3.512(4)(b) 40D-3.037(1) 62-532.500(2)(b)	Failure to extend casing from land surface continuously into a consolidated stratum immediately overlying the producing aquifer.	500	5
		Casing, Caving Zones or Screen, Caving Zones		
81	40A-3.512(7) 40B-3.512(4) 40C-3.512 40D-3.037(1) 40E-3.512(3) 62-532.500(2)(b)	Failure to case, line or screen all caving zones within the well. Note: Citation number 81 should be used only if numbers 78, 79 or 80 are not used.	500	5
		Casing, Sand Production or Screen, Sand Entrance		
82	40A-3.512(7) 40C-3.512(7)(b)	Failure to construct a well which prevents the entrance of sand into the well.	250	2.5
		Casing, Telescoped, Centralizers		
83	40C-3.512(5)(a)	Failure to use the minimum number of centralizers required by rule (continued next page)	250	2.5

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY POINTS	
	40D-3.507(3)	between the external and internal telescoping casing when the internal casing is grouted.		
	40C-3.512(5)(a)	Failure to seal a telescoped well meeting paragraph 40C-3.517(4)(c) requirements with one packer and one centralizer.	250	2.5
	62-532.500(2)(c)	For a public water system, failure to use not less than two centralizing spacers in the overlapped section of telescoping casing.	250	2.5
		Casing, Overlap		
84	40B-3.517(7) 40C-3.512(5)(a) 40D-3.507(3)	Failure to join telescoping casing with an appropriate overlap.	500	5
	62-532.500(2)(c)	For a public water system, failure to join telescoping casing with an appropriate overlap.	500	500
		Contamination, Backflow Prevention		
85	Reserved			
		Grouting, Annular Seal		
86	40A-3.517 40B-3.517(1) 40C-3.517 40D-3.517 40E-3.517	Failure to grout or seal a well to prevent movement of water from surface to aquifer or between aquifers.	1000	10
87	40A-3.517 40C-3.517 40D-3.037(1) 40D-3.517 40E-3.512(4) 62-532.500(2)(f)1	Failure to seat casing into consolidated formation or seal with neat cement grout.	1000	10

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY POINTS	
88	Reserved			
		Grouting, Special Criteria (NFWWMD)		
89	40A-3.517(1)	Failure to provide the minimum 2 inch grout layer between the bore hole and casing for all wells constructed by rotary methods south of the grout line established in Appendix I.	500	5
	40A-3.517(1)(a)	Failure to provide 2 inch grout layer in annulus from bottom of casing to land surface for wells completed into a consolidated formation with rotary drilling method.	500	5
	40A-3.517(1)(b)	Failure to provide 2 inch grout layer in annulus from screen to land surface when well is completed into an unconsolidated formation using rotary method and meeting 40A-3.517(1)(b)1-6. criteria.	500	5
	40A-3.517(1)(c)	Failure to properly seal any well constructed by rotary method into an unconsolidated formation, which does not meet the criteria of 40A-3.517(1)(b), by filling the annulus with uncontaminated compacted sand and grouting the top of the casing with 1 cu-ft of cement.	500	5
	40A-3.517(2)(a)	Failure to construct a well by rotary method north of grout line established by Appendix I, in accordance with 40A-3.517(2)(a), if the well is a Public Supply, 6 inch diameter or larger, is within 1000 feet of a pollution source, or after approved exemption is within 75 feet of a septic system.	500	5
	40A-3.517(2)(b)	Failure to grout 2 inch annulus a minimum of 20 feet from bottom of casing into the last confining layer and grout top of casing with 1 cu-ft of cement, when well is completed into a consolidated formation using rotary method and well does not meet 40A-3.517(2)(a) requirements.	500	5
	40A-3.517(2)(d)	Failure to seal annulus with uncontaminated sand and top of casing with 1 cu-ft of cement when using rotary method on wells which do not meet 40A-3.517(2)(c) criteria.	500	5

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
90	40A-3.517(2)(c)	Failure to grout 2 inch annulus from top of screen to land surface when using rotary method drilling into an unconsolidated formation, if the well is a Public Supply well, Other Public well, is 6 inch diameter or larger, penetrates a confining bed, is within 1000 feet of a pollution source, or after exemption within 75 feet of a septic system.	500	5
Grouting, Special Criteria (SJRWMD) (SWFWMD)				
91	40C-3.512(8) 40C-3.517(8)(a)2. 40D-3.517(2)(b) 40E-3.517(6) 62-532.200(4)	Failure to follow requirements for the use of bentonite grouts.	500	5
Grouting, Public Supply Well Criteria				
92	40A-3.517(3)(b) 40A-3.952 40C-3.041(5) 40D-3.037(1) 40E-3.502(b) 62-532.500(2)(f)3 62-555.315(2)(b)4	Failure to meet requirements of Rule 62-532.500(2)(f)3. when grouting public water supply or limited use systems wells.	1000	10
Grouting				
93	40B-3.517(2) 40C-3.517(2) 40D-3.037(1) 40D-3.507(4) 40E-3.517(2) 62-532.500(2)(f)4	Failure to seal the annular space surrounding the entire length of a casing less than 4 inches in outside diameter with a nominal one inch thickness of grout in a consolidated formation.	500	5
	40B-3.517(3) 40C-3.517(3)	Failure to seal the annular space surrounding the entire length of a casing equal to or greater than four (4) inches in outside diameter with a nominal (continued next page)	500	5

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
	40D-3.037(1) 40D-3.507(4) 40E-3.517(2) 62-532.500(2)(f)4	two (2) inch thickness of grout in a consolidated formation.	500	5
		Grouting, Confining Beds Absent, Special Criteria (SRWMD)		
94	40B-3.517(4)	Failure to grout to the top of or ten (10) feet into the confining bed overlying the producing aquifer, whichever is less.	500	5
	40B-3.517(5)	Failure to grout from the bottom of the casing to the top of the producing aquifer where confining beds are absent.	500	5
		Grouting, Unconsolidated		
95	40A-3.517(1)(b),(2)(c) 40C-3.517(5) 40E-3.517(3)	Failure to seal all non-caving annular space in an unconsolidated stratum with neat cement grout.	500	5
	40C-3.517(6) 40C-3.517(7)(a) 40D-3.037(1) 40D-3.517 62-532.500(2)5.	Failure to properly grout a well obtaining water from an unconsolidated formation.	500	5
96	40E-3.517(3)	Failure to grout the annular space of wells constructed in unconsolidated formations not more than ten feet above the top of the screen, to land surface.	500	5
97	Reserved			
		Grouting, Combination Wells, Pilot Hole Driving		
98	40C-3.517(11)(a) 40E-3.517(7)(c) 62-532.500(2)(f)4.	Failure to grout from bottom of casing to land surface any driven casing which is placed in a bore hole of larger diameter. (continued next page)	500	5

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
	40C-3.517(11)(a) 40D-3.037(1)	Failure to use a drilling bit smaller in diameter than the outside diameter of a driven casing.	500	5
		Note: When citing 98, do not include citations 93 or 100.		
		Grouting, Upper Three Feet, Driven Casing		
99	Reserved			
		Grouting, Methods		
100	40A-3.517(4)(6) 40C-3.517(8)(e) 40D-3.037(1) 40D-3.517 40E-517(1) 62-532.500(2)(f)4.	Failure to use a tremie pipe or other approved methods when grouting or sealing the annular space.	500	5
	40A-3.517(4)(c) 40B-3.517(8)(d) 40C-3.517(8)(e) 40D-3.037(1) 40D-3.517(1),(2) 40E-3.517(1) 62-532.500(2)(f)4.	Failure to introduce grout from bottom to top in the annular space.	500	5
	40C-3.517(11)(c) 40D-3.517(3) 62-532.500(2)(f)2.	Failure to seal driven casing using dry bentonite.	500	5
101	40A-3.517 40C-3.041(5) 40D-3.037(1) 62-532.500(f)4.	Failure to seal the annular space of any Public Supply well casing when the bore hole exceeds the outside diameter of the casing with neat cement from bottom to top.	1000	10

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Grouting, Mixing Requirements		
102	40A-3.517(4)(a) 40B-3.517(8)(a) 40C-3.517(8)(a)1.,2. 40D-3.517(2)(a)1.,(b) 40E-3.517(6) 62-532.500(2)(f)6.	Failure to use the designated mixture of grout Note: Reference is made in rules to AWWA Standard A100-97 as revised and used as a base in the development of the criteria listed in 62-532.500(2).	500	5
103	Reserved			
		Grouting, Centering Casing		
104	40A-3.517(4)(b) 40B-3.517(8)(c) 40C-3.517(8)(d) 40D-3.037(1) 40D-3.517 40E-3.517(1) 62-532.500(2)(f)4.	Failure to center the casing in the bore hole prior to grouting and sealing the annular space.	500	5
		Grouting, Set Time		
105	40A-3.517(4)(d)	Failure to observe the minimum set time for grout as specified in 40A-3.517 Table III, before proceeding.	500	5
	40B-3.517(8)(b) 40C-3.517(8)(b) 40D-3.517(2)(a)2. 40E-3.517(1)	Failure to allow 12 hours set time for grout before proceeding with drilling operations.	500	5
106	Reserved			

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Grouting, Telescoped Casing		
107	40B-3.517(7) 40C-3.512(5) 40C-3.517(4)(a) 40D-3.507(3) 40E-3.517(1) 62-532.500(2)(b)	Failure to seal the annular space between telescoping casing with grout, packers or both. Note: The Department considers a telescoped casing continuous provided the grout requirements are satisfied.	500	5
	40D-3.507(3)	Use of lead packers between casings	500	5
108	Reserved			
		Grouting, Special Criteria, Telescoped Casing (SJRWMD)		
109	40C-3.517(4)(c)	Failure to use a nominal external casing size of four (4) inches or less to construct a telescoped well in areas where caving clays are used in place of grout.	500	5
	40C-3.517(4)(c)	Failure to show that the clay materials are of a caving nature when installing a telescoped interior casing without annular grout.	500	5
	40C-3.517(4)(c)	Failure to limit the annular space to one inch or less around the internal telescoping casing where caving clay materials are present.	500	5
		Grouting, Lost Circulation		
110	40A-3.517(6) 40B-3.517(10) 40C-3.517(7) 40D-3.037(1) 40D-3.517 40E-3.517(1) 40E-3.531(3)(a)	Failure to use approved methods and materials to bridge a lost circulation zone during grouting operations.	500	5

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
		Well Seal, Temporary, Penetrating to Aquifer		
111	40A-3.521(1) 40B-3.521(1) 40C-3.521(1) 40D-3.037(1) 40D-3.521(1) 40E-3.517(8) 62-532.500(3)(a)1.	Failure to seal the well opening of a well penetrating the aquifer with a tamper resistant cover when there is a temporary interruption in work or use.	350	3.5
112	Reserved			
		Well Seal, Permanent, Above Flood Level		
113	40A-3.521(2) 40B-3.521(2) 40C-3.521(2)(a, b) 40D-3.521(2) 40E-3.517(9) 62-532.500(3)(b)5.	Failure to seal the upper terminus of well casing with a water tight seal.	500	5
		Well Vent, Above Flood Level		
114	40A-3.521(2) 40B-3.521(2) 40C-3.521(2)(b) 40D-3.037(1) 40D-3.521(4) 40E-3.517(9)	Failure to vent above the 100-year flood level or two (2) feet above land surface.	150	1.5
		Inspection Port		
115	40A-3.521(2) 40B-3.521(2) 40C-3.521(2)(e)	Failure to install a required inspection port.	250	2.5
		(continued next page)		

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
	40D-3.021(18) 40D-3.037(1) 40E-3.517(9) 62-532.500(3)(b)6.	Failure to install a required inspection port.	250	2.5
		Well Seal, Pump Installed		
116	40A-3.521(2) 40B-3.521(2) 40C-3.521(2)(c) 40D-3.521(3) 40E-3.517(9) 40E-3.521(2)(c) 62-532.500(3)(a)3.	Failure to install pumping equipment, piping or electrical equipment through a well seal.	250	2.5
117	Reserved			
		Explosives, Approval of		
118	40A-3.525 40B-3.525 40C-3.525 40D-3.525 40E-3.525	Failure to receive FDEP and District approval prior to the use of explosives in well construction or development.	1000	10
	62-532.500(2)(e)	Failure to receive a variance from the FDEP prior to the use of explosives in well construction or development..	1000	10
		Flowing Wells, Valve Controls		

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED PENALTY	POINTS
119	40A-3.529 40B-3.529 40C-3.529 40D-3.529 40E-3.529 62-532.500(3)(d)	Failure to valve an artesian well discharging at land surface.	1000	10
Abandonment, Methods				
120	40A-3.531(4),(5) 40B-3.531(2) 40C-3.517(9) 40C-3.531(1,2,3) 40D-3.531(1) 40E-3.531(2)	Failure to plug an abandoned artesian well bottom to top with grout using a Licensed Water Well Contractor.	1000	10
Abandonment, Suitable Use or Standards Violation				
121	40A-3.531(2)(a)	Failure of Licensed Water Well Contractor to plug any well which is not completed or suitable for its intended use before removing the well rig from the job site.	500	5
	40A-3.531(1),(3) 40D-3.461(2) 40D-3.531 40E-3.531(1)	Failure to plug any well not constructed in accordance with this rule.	1000	10
Abandonment, Timeframe				
122	40A-3.531(2)(a) 40E-3.531(3)	Failure to plug an abandoned well within the time specified by the District in writing.	250	2.5
Abandonment, Restore Hydrologic Conditions				

FLORIDA UNIFIED CITATIONS DICTIONARY FOR WATER WELL CONSTRUCTION

NO.	RULE CITATION	SECTION TITLE AND TEXT	RECOMMENDED	
			PENALTY	POINTS
123	40D-3.037(1) 40E-3.531(3)	Failure to restore or improve the hydrologic conditions after the well is plugged.	1000	10