

Florida Power and Light Turkey Point Monitoring

Laboratory Analyses of Samples

Validated Chemistry Data posted January 20, 2011

[Download](#) 

Download a Microsoft Excel .xls spreadsheet file of the Level 4-validated August 2010 Biscayne Bay Porewater tracer suite sampling event resultst

Tritium is one of the parameters being measured as a potential tracer for identifying contributions of the cooling canal system water as a source of ground water or surface water occurrences. The Florida Department of Environmental Protection drinking water standard for concentrations of tritium in groundwater is 20,000 pCi/L. All measured concentrations of tritium collected and reported herein are well below this regulatory standard used for identifying the potential for human health risks.